



960 Flaherty Drive
New Bedford, MA 02745

OFFICE / 732-866-0705
TOLL FREE / 800-658-9657
FAX / 732-866-0907
WEB / afcweb.com

February 16, 2015

To whom it may concern,

Subject: Approval of AFC's Luminary™ Cable (Type MC-PCS) for use in New York City.

In response to customer questions regarding the acceptability of AFC's Luminary™ Cable (UL Listed Type MC-PCS) for use in New York City, a formal interpretation was requested from the NYC Electric Code Review and Interpretation Committee (ECRIC). The ECRIC has responded that Yes, the cable is approved for use in the City of New York.

The traditional way for conveying a response from the ECRIC is to have it posted to the NYC Department of Buildings website. The website will be updated in about one month's time.

http://www.nyc.gov/html/dob/html/codes_and_reference_materials/ecric.shtml

The ECRIC Webmail site is temporarily down and a response by way of the ECRIC website is expected within a week.

The following is the response to AFC's Electrical Code Interpretation Request (ED-76) of January 29, 2015.

Inquiry:

Can an electrical cable containing conductors for electric light that are separated from conductors for Class 2 or class 3 circuits within the same cable in accordance with 725.136(l) be used for connection to a lighting device requiring both power and control conductors?

Answer:

Yes, when listed as such and designated with "-PCS", and having a minimum inner jacket thickness of 30 mils or more.



Columbia-MBF



KAF-TECH



UNISTRUT



UNISTRUT Construction



Please Contact me if specific information related to the approval is needed while the City's website is updated and until the ECRIC Website is back on line.

Very truly yours,



George A. Straniero
Manager Codes and Standards
AFC Cable Systems, Inc.
gstraniero@afcmail.com
732-866-0705

CC: J. Hou-AFC, VP Marketing
K. Lamarre-AFC, VP Sales
L. Brigham -AFC, Director NE Sales
M. Abbassi-NYC, Chairman ECRIC